

## KUJAWY CEMENT PLANT IN BIELAWY

Holcim Polska S.A.  
Kujawy Cement Plant  
Technical Support

tel.: (52) 58 65 000, fax: (52) 58 65 011  
tel.: (41) 24 87 533, fax: (41) 24 87 531

### Quality Certificate of cement

Type of cement : **CEM I 42,5R**

Requirements acc. to: EN 197-1:2011

Values obtained for the period of: **June 2024**

	Unit	Results	Requirements acc. to: EN 197-1:2011
--	------	---------	--

#### 1. Properties (by standards)

Compressive strength			
Early strength, after 2 days	MPa	26,4	≥ 20
Standard strength, after 28 days <small>(results from previous month)</small>	MPa	57,9	≥ 42,5 i ≤ 62,5
Initial setting time	min	210	≥ 60
Expansion of cement	mm	0,5	≤ 10
Sulfate content (as SO <sub>3</sub> )	%	3,21	≤ 4,0
Chloride content Cl <sup>-</sup>	%	0,062	≤ 0,10
Loss on ignition <sup>a)</sup>	%	3,90	≤ 5,0
Insoluble residues <sup>a)</sup>	%	1,45	≤ 5,0

#### 2. Additional information

Laser particle size distribution passing 8 μm/32 μm	%	31/77	-
--	---	-------	---

a)only for CEM I and CEM III

*Anna Kozłowska*

Kierownik Jakości  
Cementownia Kujawy w Bielawach

.....  
stamp/signature

Holcim Polska S.A.

ul. Warszawska 110, 28-366 Małogoszcz  
NIP: 526-10-60-765, REGON: 011843520  
KRS: 0000062569 (Sąd Rejonowy w Kielcach X Wydział Gospodarczy KRS)  
Kapitał akcyjny: 811.329.500 opłacony w pełni, nr rejestracyjny BDO 000001937

www.holcim.pl